



Massachusetts Department of Environmental Protection
Bureau of Waste Prevention – Industrial Wastewater
BWP IW 38 & BWP IW 39
Permit for Industrial Sewer User

X005431

Transmittal Number

Facility ID# (if known)

MassDEP Use Only

Special Conditions:

1. This permit shall supersede Millenium Power Partners, L.P.'s Industrial Wastewater Sewer Connection Renewal Permit #W034602 if it is issued and becomes effective on or before Permit #W034602 expires (October 8, 2008). Should this permit not be issued and/or not become effective on or before Permit #W034602 expires, Permit #W034602 shall continue in effect until this permit is issued and becomes effective.
2. The permittee shall maintain compliance with the Town of Charlton's sewer use requirements and the terms and conditions of any applicable wastewater discharge permits issued by the Town of Southbridge.
3. The permittee shall comply with the Effluent Guidelines and Standards at 40 CFR, Chapter I, Subchapter N, Part 423.17 – Steam Electric Power Generating Point Source Category.
4. The permittee shall the notify MassDEP of additional Effluent Guidelines and Standards as they are determined to be applicable to the facility.
5. The permittee shall inspect its oil/water separator (described in the Industrial Wastewater Sewer Connection Renewal Permit #W034602) a minimum of once per month. When the level of floating oil exceeds six (6) inches or when the depth of sediment in the bottom of the separator exceeds six (6) inches, the permittee must contract with a licensed hazardous waste disposal contractor to dispose of the oily waste or sediment properly. The permittee shall submit a copy of all inspection reports and a copy of the generator's portion of the hazardous waste hauling manifests to the Town of Southbridge Water and Sewer Department (i) with respect to the inspection reports, by the 15th day following the end of each quarter and (ii) with respect to the hazardous waste hauling manifests, by the 15th day of the month following the oil or sediment removal activity.
6. The permittee shall maintain on site and update and implement as necessary the High POTW Flow Standard Operating Procedure ("HPF-SOP"). The HPF-SOP was required as part of MassDEP's written approval of the permittee's wastewater discharge mitigation plan, issued December 21, 1999, and incorporates the elements of the plan and the definitions of action thresholds. The plan is in place to prevent hydraulic overloading of the Town of Southbridge's wastewater treatment plant by the permittee.
7. The documents and materials attached to and referenced in the permit application are incorporated as part of the permit.

This document is a permit issued pursuant to Massachusetts General Laws, Chapter 21, Section 43 and Massachusetts regulations at 314 CMR 7.00. The permittee shall comply with all of the provisions contained in the permit application which are hereby incorporated and made part of this permit.

Date Issued

Permit Effective Date

Permit Expiration Date

Name of Regional BWP Section Chief

Signature